



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Aero-Tech

ACTIVE

2900 Gary Drive
Plymouth IN 46563

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		EFFECTIVE GALLONS	TOTAL	APPROVAL USE	APPROVAL DATE	FAMILY
				WIDTH	LENGTH		GALLONS (Pump Tanks)			
70-147-AT2-C3	C3	0.25	66.00	64	64	835		ATU	7/6/2010	
REMARKS: Fiberglass. Houses Aero-Tech AT-500 gallon per day ATU. Requires 500 gallon minimum pretreatment tank. W/o clarifier can be pretreatment tank to AT-750 ATU										
70-147-AT3-C3	C3	0.25	66.00	64	64	835		ATU	7/6/2010	
REMARKS: Fiberglass. Houses Aero-Tech AT-600 gallon per day ATU. Requires 600 gallon minimum pretreatment tank. W/o clarifier can be pretreatment tank to AT-750 ATU										
70-147-AT4-C3	C3	0.25	66.00	72	72	1050		ATU	7/6/2010	
REMARKS: Fiberglass. Houses Aero-Tech AT-750 gallons per day ATU. Requires 750 gallon minimum pretreatment tank. W/o clarifier can be pretreatment tank to AT-1000 ATU										
70-147-AT5-C3	C3	0.25	66.00	84	84	1450		ATU	7/6/2010	
REMARKS: Fiberglass. Houses Aero-Tech AT-1000 gallons per day ATU. Requires 1000 gallon minimum pretreatment tank.										
70-147-AT6-C3	C3	0.25	72.00	96	96	2100		ATU	12/20/2010	
REMARKS: Fiberglass. Houses Aero-Tech AT-1500 gallons per day ATU. Requires 1500 gallon minimum pretreatment tank.										



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Alpha General Services, Inc.

ACTIVE

Highlands

Post Office Box 3331

Sebring, FL 33871

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		EFFECTIVE GALLONS	TOTAL	APPROVAL	FAMILY
							GALLONS (Pump Tanks)		
28-004-18S-C3	C3	0.25	50.00			1300	1,552	ATU	3/22/2002

REMARKS: for use with BIO-Microbics ATUs MF 0.5, when used with 350gal min. settling tank; MF 0.75 when used with a 375 gal min. settling tank; MF 0.9 when used with a 500 gal min. settling tank; all in lid installation.

28-004-BM1-C3	C3	0.25	49.00			1300	1,552	ATU	2/6/2008
---------------	----	------	-------	--	--	------	-------	-----	----------

REMARKS: slide-in baffle located for use with BIO-Microbics ATUs MF 0.5; MF 0.75; MF 0.9; all in lid installation.



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

AquaKlear, Inc.

ACTIVE

870 Bierdeman Road

Pearl MS 39208

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
							GALLONS (Pump Tanks) USE		
70-114-05-C3	C3	0.25	50.50					12/30/2004	
REMARKS: fiberglass tank-houses the 500 gallon per day AquaKlear ATU									
70-114-06-C3	C3	0.31	55.00					5/24/2002	
REMARKS: fiberglass tank-houses the 600 gallon per day AquaKlear ATU									
70-114-08-C3	C3	0.38	56.50					12/30/2004	
REMARKS: fiberglass tank-houses the 800 gallon per day AquaKlear ATU									
70-114-10-C3	C3	0.44	56.50					12/30/2004	
REMARKS: fiberglass tank-houses the 1000 gallon per day AquaKlear ATU									
70-114-15-C3	C3	0.44	68.00	65	136			12/5/2006	
REMARKS: fiberglass tank-houses the 1500 gallon per day AquaKlear ATU									
70-114-75-C3	C3	0.38	56.50					12/30/2004	
REMARKS: fiberglass tank-houses the 750 gallon per day AquaKlear ATU									



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Averett Septic Tank Co.

ACTIVE

Polk

Post Office Box 266

Eaton Park, FL 33840

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		EFFECTIVE GALLONS	TOTAL	APPROVAL USE	APPROVAL DATE	FAMILY
				WIDTH	LENGTH		GALLONS (Pump Tanks)			
53-037-H10P-C3	C3	2.75	65.00	89	157	3309		ATU	7/18/2002	
REMARKS: Houses the Hoot 1000 gpd dosed ATU system (H-1000 AND), needs settling tank.										
53-037-H5-C3	C3	3.00	52.00	74.5	106	1320		ATU	3/22/2002	
REMARKS: discontinued. Used to house Hoot 500 gpd gravity flow ATU (H-500 A). Can also house Hoot 600 gpd gravity flow ATU (H-600 A)										
53-037-H6G-C3	C3	3.00	52.00	74.5	106	1320		ATU	3/22/2002	
REMARKS: Houses either the Hoot 500 or 600 gpd gravity flow ATU (H-500 A, H-600 A).										
53-037-H6P-C3	C3	3.00	52.00	74.5	160	2080				
REMARKS: Houses either the Hoot 500 or 600 gpd dosed ATU (H-500 AND, H-600 AND). Needs recirculation for increased nitrogen reduction.										
53-037-H7P-C3	C3	3.00	56.50	62	174		1,960		3/24/2008	
REMARKS: Houses the Hoot 500 gpd ATU (H-500). Not intended for nitrogen reduction. Can be used for gravity or low pressure distribution systems.										



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Baker Septic Installations, Inc.

ACTIVE

Highlands

7740 South George Blvd.

Sebring, FL 33875

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		EFFECTIVE GALLONS	TOTAL	APPROVAL	FAMILY
				WIDTH	LENGTH		GALLONS (Pump Tanks) USE		
28-031-DF50-C4	C4	3.00	51.50			900		6/21/2010	

REMARKS: Circular tank-Houses Delta 500 gpd DFXX-CA ATU

28-031-J1-C3	C3	3.00	50.00	0	0	1160	1,494	ATU ta	10/30/2006
--------------	----	------	-------	---	---	------	-------	--------	------------

REMARKS: Houses Jet Models J-500 thru J-1500 ATU's



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Bingham Onsite Precasting Inc.

ACTIVE

Polk

6172 Highway 640 West

Mulberry FL 33830

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		EFFECTIVE GALLONS	TOTAL	APPROVAL	FAMILY
							GALLONS (Pump Tanks)		
53-137-A1-C3	C3	3.00				500	ATU	3/22/2002	
REMARKS: Used to house the Alliance ATU									
53-137-C/A-C3	C3	3.00	52.50			750	ATU	3/22/2002	
REMARKS: Used to house the Cajun-Aire 500 & 750 ATU									
53-137-MM1-C4	C4	0.38	66.00				ATU	3/22/2002	
REMARKS: Used to house the Mighty Mac 500 ATU									
53-137-MM2-C3	C3	0.38	66.00				ATU	10/6/2002	
REMARKS: Used to house the Mighty Mac 750 ATU									
53-137-MM3-C3	C3	0.38	66.00				ATU	10/6/2002	
REMARKS: Used to house the Mighty Mac 600 ATU									



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Bonded Septic Tank

ACTIVE

Citrus

P.O. Box 1509-State Rd 486

Hernando, FL 34442

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		EFFECTIVE GALLONS	TOTAL	APPROVAL	FAMILY
				WIDTH	LENGTH		GALLONS (Pump Tanks) USE		
09-030-11D-C3	C3	3.00	43.25	64	120.5	1114	1,337	6/3/2008	

REMARKS: Used to house Bio-Microbics FAST 0.5 and 0.75 ATU.

09-030-11S-C3	C3	3.00	43.25	64	120.5	1138	1,337	6/3/2008	
---------------	----	------	-------	----	-------	------	-------	----------	--

REMARKS: When used with a 450 to 900 gallon settling tank used to house FAST 0.9 ATU. Also, when used with a 750 to 1500 gallon settling tank, used to house FAST 1.5 ATU.



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Bord na Mona

ACTIVE

P.O. Box 77457

Greensboro NC 27417

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u> WIDTH	EFFECTIVE LENGTH	TOTAL	APPROVAL	FAMILY
						GALLONS (Pump Tanks) USE		
70-130-01S-TM	TM	0.25					3/30/2005	

REMARKS: Polyethylene tank used to house 12" above ground 7'L x 4.5'W x 2.5'D Puroflo Peat Biofilter ATU



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Brooks Concrete

ACTIVE

Wakulla

P. O. Box 82
Panacea, FL 32346

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH		GALLONS (Pump Tanks)		
65-073-BM1-C3	C3	2.50	40.50	60	102	850	ATU	9/12/2007	
REMARKS: Houses Bio-Microbics shortened MicroFAST 0.5 MicroFAST 0.75 or MicroFAST 0.9 ATU. Settling tanks required (350-500gal for 0.5; 375-750gal for 0.75; 500-900gal for 0.9). Modification of tank 04S-C3.									
65-073-BM2-C3	C3	2.50	42.88	60	102	900	ATU, s	10/15/2007	
REMARKS: Single compartment tank with two sets of notches for slide-in baffles: standard baffle for use as dual compartment septic tank; baffle with center of pass-through hole at 24 in above bottom for use with special lid and Bio-Microbics MicroFAST 0.5 ATU in lid installation.									
65-073-BM3-C3	C3	2.50	40.50	60	119	900	ATU	11/19/2007	
REMARKS: monolithic baffle set to house Bio-Microbics shortened MicroFAST 0.5 ATU									
65-073-NW1-C3	C3	2.50	54.00					12/24/2001	
REMARKS: Norweco (Singulair 960 and Singulair TNT model) 500/600 gallon per day ATU. Add 1000 gallon pretreatment chamber to become 1000 gallon per day ATU.									
65-073-NW2-C3	C3	2.50	66.00					8/28/2002	
REMARKS: Norweco (Singulair 960 and Singulair TNT model) 750/800 gallon per day ATU. Add 1250 pretreatment chamber to become 1250 gallon per day ATU.									
65-073-NW3-C3	C3	3.00		72	111		ATU	4/30/2007	
REMARKS: Houses Norweco (Singulair 960 and Singulair TNT model) 500 and 600 gpd ATU's. Also, with 1000 gallon pretreatment tank it houses 1000 gpd ATU									



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Caribe Jet, Inc.

ACTIVE

Polk

4753 E. Highway 92

Lakeland FL 33801

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		EFFECTIVE GALLONS	TOTAL GALLONS		APPROVAL	
				WIDTH	LENGTH		(Pump Tanks)	USE	DATE	FAMILY
53-131-J1-C3	C3	3.00	50.00			1160	1,494	ATU	8/22/2005	

REMARKS: Houses Jet Models J-500 thru J-1500 ATU's



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Cast Systems LLC.

ACTIVE

Charlotte

19400 Peachland Blvd.

Port Charlotte FL 33954

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		EFFECTIVE GALLONS	TOTAL	APPROVAL USE	DATE	FAMILY
				WIDTH	LENGTH		GALLONS (Pump Tanks)			
08-123-AK1-C3	C3	3.00	51.00			750		ATU	2/11/2003	
REMARKS: used to house the AquaKlear AK500S96F ATU										
08-123-DF50-C3	C3	3.00	52.25			919	1,057	ATU	7/2/2003	
REMARKS: used to house the Delta Whitewater DF50-CA or UC50-CA ATU										



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Clearstream Wastewater Systems, I ACTIVE

P.O. Box 7568

Beaumont TX 77726-7568

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		EFFECTIVE GALLONS	TOTAL	APPROVAL	FAMILY
							GALLONS (Pump Tanks)		
70-120-05N-C3	C3	0.25	63.00				ATU ta	11/5/2002	
REMARKS: Fiberglass tank-houses Clearstream 500 gallon per day ATU									
70-120-06N-C3	C3	0.31	55.00				ATU ta	11/5/2002	
REMARKS: Fiberglass tank-houses Clearstream 650 gallon per day ATU									
70-120-07N-C3	C3	0.31	65.00				ATU ta	11/5/2002	
REMARKS: Fiberglass tank-houses Clearstream 750 gallon per day ATU									
70-120-10N-C3	C3	0.38	87.00				ATU ta	11/5/2002	
REMARKS: Fiberglass tank-houses Clearstream 1000 gallon per day ATU									
70-120-15N-C3	C3	0.44	82.00				ATU ta	11/5/2002	
REMARKS: Fiberglass tank-houses Clearstream 1500 gallon per day ATU									



DEPARTMENT OF HEALTH
 STATE HEALTH OFFICE
 SEPTIC TANK DESIGNATED APPROVAL NUMBERS
 SEPTIC TANK MANUFACTURERS
 run date: 4/5/2012
 Searching for: atu

Consolidated Treatment Systems, I ACTIVE

1501 Commerce Center Drive
 Franklin OH 45005

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR WIDTH	TOP EXTERIOR LENGTH	EFFECTIVE GALLONS	TOTAL GALLONS (Pump Tanks)	APPROVAL USE	APPROVAL DATE	FAMILY
70-113-EG1-C3	C3		64.00						2/25/2005	
REMARKS: fiberglass-houses Enviro-Guard 750 gpd ATU										
70-113-MF1-C3	C3		54.00						5/20/2002	
REMARKS: fiberglass-houses MULTI-FLO FTB 0.5 (500 gpd) ATU										
70-113-MF2-C3	C3		54.00						5/20/2002	
REMARKS: fiberglass-houses MULTI-FLO FTB 0.6 (600 gpd) ATU										
70-113-MF3-C3	C3		58.00						5/20/2002	
REMARKS: fiberglass-houses MULTI-FLO FTB 0.75 (750 gpd) ATU										
70-113-MF4-C3	C3		64.00						5/20/2002	
REMARKS: fiberglass-houses MULTI-FLO FTB 1.0 (1000 gpd) ATU										
70-113-MF5-C3	C3		54.00						5/20/2002	
REMARKS: fiberglass-houses MULTI-FLO FTB 1.5 (1500 gpd) ATU										
70-113-N1-C3	C3		62.50						5/20/2002	
REMARKS: fiberglass-houses NAYADIC M6-A (500 gpd) ATU										
70-113-N1A-C3	C3	0.19	62.50	72	72	500		ATU	1/26/2012	
REMARKS: fiberglass-houses NAYADIC M6-A (500 gpd) ATU										
70-113-N2-C3	C3		68.00						5/20/2002	
REMARKS: fiberglass-houses NAYADIC M8-A (600 gpd) ATU										
70-113-N3-C3	C3		75.50						5/20/2002	
REMARKS: fiberglass-houses NAYADIC M1050-A (800 gpd) ATU										
70-113-N4-C3	C3		86.00						5/20/2002	
REMARKS: fiberglass-houses NAYADIC M1200-A (1000 gpd) ATU										
70-113-N5-C3	C3		96.50						5/20/2002	
REMARKS: fiberglass-houses NAYADIC M2000-A (1500 gpd) ATU										



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Del Zotto Mfg. Co.

ACTIVE

Marion

4405 W. Hwy. 40

Ocala, FL 34482

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH		GALLONS (Pump Tanks) USE		
42-007-08D-C3	C3	2.50	42.00			1050		11/13/2002	
REMARKS: Houses Bionest BNC-400 ATU.									
42-007-08D-C4	C4	4.00	42.00			1050		11/13/2002	
REMARKS: Houses Bionest BNC-400 ATU.									
42-007-30D-C3	C3	4.00	42.00			1900		2/4/2002	
REMARKS: Houses Bionest BNC-750 ATU.									
42-007-49D-C3	C3	4.00	60.00			2700		2/4/2002	
REMARKS: Houses Bionest BNC-1000 ATU.									
42-007-CS1-C3	C3	3.00	57.00	0	0		ATU	6/6/2007	
REMARKS: Monolithic tank-Houses 600 gpd Clearstream Model 600NC3T ATU									
42-007-JT1-C4	C4	3.00	52.38	61.63	123		ATU	1/15/2009	
REMARKS: Used to house the Jet 500 and 750 GPD ATU. With pretreatment tank, used to house Jet 1000, 1250, and 1500 GPD ATU									



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Delta Environmental Products, Inc. ACTIVE

P.O. Box 969

Denham Springs LA 70727

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR WIDTH	TOP EXTERIOR LENGTH	EFFECTIVE GALLONS	TOTAL GALLONS (Pump Tanks)	APPROVAL USE	APPROVAL DATE	FAMILY
70-115-DF1-C3	C3	0.31	51.56						6/11/2002	
REMARKS: Fiberglass tank-Houses Delta DF50-FF or UC50-FF ATU @ 500 gpd										
70-115-DF2-C3	C3	0.31	59.50						6/11/2002	
REMARKS: Fiberglass tank-Houses Delta DF60-FF or UC60-FF ATU @ 600 gpd										
70-115-DF3-C3	C3	0.38	64.00						6/11/2002	
REMARKS: Fiberglass tank-Houses Delta DF75-FF or UC75-FF @ 750 gpd, or UC90-FF ATU @ 900 gpd										
70-115-DF4-C3	C3	0.38	61.00						6/11/2002	
REMARKS: Fiberglass tank-Houses Delta DF100A-FF or UC100A-FF ATU @ 1000 gpd										
70-115-DF5-C3	C3	0.38	91.50						6/11/2002	
REMARKS: Fiberglass tank-Houses Delta DF150-FF or UC150-FF ATU @ 1500 gpd										



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Ecological Tanks, Inc.

ACTIVE

2247 Highway 151 N.

Downsville LA 71234

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		EFFECTIVE GALLONS	TOTAL	APPROVAL	FAMILY
							GALLONS (Pump Tanks)		
70-125-AS10-C3	C3	0.47	90.00				ATU ta	6/3/2003	
REMARKS: Houses the Aqua Safe 1000 ATU									
70-125-AS15-C3	C3	0.47	90.00				ATU ta	6/3/2003	
REMARKS: Houses the Aqua Safe 1500 ATU									
70-125-AS5-C3	C3	0.40	67.50				ATU ta	6/3/2003	
REMARKS: Houses the Aqua Safe 500 ATU									
70-125-AS6-C3	C3	0.40	67.50				ATU ta	6/3/2003	
REMARKS: Houses the Aqua Safe 600 ATU									
70-125-AS7-C3	C3	0.45	67.50				ATU ta	6/3/2003	
REMARKS: Houses the Aqua Safe 750 ATU									



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Florida Septic, Inc.

ACTIVE

Alachua

Post Office Box 545

Hawthorne, FL 32640

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH		GALLONS (Pump Tanks)		
01-011--C4	C4	6.00	72.00			5000			
REMARKS: Converted 77D om 2-03-2012. Houses Bio-Microbics 3.0 ATU. AASHTO H20 traffic loading rated when buried between 18" to 48"									
01-011-07S-C3	C3	2.50	51.75			1050	Standa	6/11/2002	
REMARKS: Can be used to house Bio-Microbics MicroFast 0.5 ATU when used with 350 gallon min. settling tank									
01-011-09D-C3	C3	2.50	50.00			1050		1/31/2001	
REMARKS: Houses Bionest BNC-400 ATU									
01-011-11D-C4	C4		44.00			1050	1,348	3/17/2003	
REMARKS: Houses Bionest BNC-400 ATU. Wall thickness can be either 4" or 6". AASHTO H20 traffic loading rated when buried between 18" to 48"									
01-011-13D-C4	C4		52.00			1250	1,564	3/17/2003	
REMARKS: Houses Bionest BNC-500 ATU. Wall thickness can be either 4" or 6". AASHTO H20 traffic loading rated when buried between 18" to 48"									
01-011-20D-C3	C3	3.00	63.00			1500		5/31/2001	
REMARKS: Houses Bionest BNC-600 ATU.									
01-011-23D-C4	C4	4.00	53.00			1500		7/30/2001	
REMARKS: Houses Bionest BNC-600 ATU									
01-011-37D-C3	C3	3.00	53.00			2000		7/30/2001	
REMARKS: Houses Bionest BNC-750 ATU									
01-011-38D-C4	C4	4.00	53.00			2000		7/30/2001	
REMARKS: Houses Bionest BNC-750 ATU									
01-011-39D-C4	C4	6.00	53.00			2000		5/29/2002	
REMARKS: Houses Bionest BNC-750 ATU. AASHTO H20 traffic loading rated when buried between 18" to 48"									
01-011-43D-C4	C4	4.00	66.00			2500		7/30/2001	
REMARKS: Houses Bionest BNC-1000 ATU									
01-011-64D-C3	C3	4.00	50.00			3300		8/14/2001	
REMARKS: Houses Bionest BNC-1250 ATU									
01-011-65D-C4	C4	6.00	49.50			3300		10/31/2001	
REMARKS: Houses Bionest BNC-1250 ATU. AASHTO H20 traffic loading rated when buried between 18" to 48"									
01-011-68D-C3	C3	4.00	54.00			3700		8/14/2001	
REMARKS: Houses Bionest BNC-1500 ATU									
01-011-69D-C4	C4	6.00	55.00			3700		5/29/2002	
REMARKS: Houses Bionest BNC-1500 ATU. AASHTO H20 traffic loading rated when buried between 18" to 48"									
01-011-AK10-C3	C3	3.00	56.50	62	119	1342	1,583	8/12/2008	
REMARKS: Houses AquaKlear AK1000C 1000 gallon per day ATU									



DEPARTMENT OF HEALTH
 STATE HEALTH OFFICE
 SEPTIC TANK DESIGNATED APPROVAL NUMBERS
 SEPTIC TANK MANUFACTURERS
 run date: 4/5/2012
 Searching for: atu

Florida Septic, Inc.

ACTIVE

Alachua

Post Office Box 545
 Hawthorne, FL 32640

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH		GALLONS (Pump Tanks)		
01-011-AK5-C4	C4	3.00	49.50			640	773	ATU ta	12/14/2005
REMARKS: Used to house AquaKlear 500 gallon per day ATU.									
01-011-AK5B-C3	C3	3.00	50.50	81.38	139.5	1875		ATU	8/27/2007
REMARKS: Houses AquaKlear AK5B3 500 gpd ATU unit and dosing pump.									
01-011-AK8-C3	C3	3.00	57.50			1020	1,193	ATU ta	12/14/2005
REMARKS: Used to house AquaKlear 800 gallon per day ATU.									
01-011-BM1-C3	C3	3.00	45.00			1100	1,479	ATU ta	10/31/2003
REMARKS: Used to house Bio-Microbics FAST 0.5FS ATU									
01-011-BM10-C4	C4	6.00	66.00			2400			3/29/2012
REMARKS: Converted 02-05-2012. Houses Bio-Microbics 1.5 ATU. AASHTO H20 traffic loading rated when buried between 18" to 48"									
01-011-BM11-C4	C4	6.00	66.00	0	0	4500	5,909	ATU	3/19/2012
REMARKS: Used to house Bio-Microbics FAST 3.0F and 3.0FS ATU. AASHTO H20 traffic loading rated when buried between 18" to 48"									
01-011-BM12-C4	C4	600.00	65.00	0	0		4,400	ATU	
REMARKS: AASHTO H20 traffic loading rated when buried between 18" to 48". Used to house Bio-Microbics FAST 4.5F ATU									
01-011-BM12-C4	C4	6.00	72.00			5000			
REMARKS: (Converted 77S to 01-011-BM12, 2-5-2012) Houses Bio-Microbics 4.5 ATU. AASTO H20 traffic loading rated when buried between 18" to 48"									
01-011-BM2-C4	C4	4.00	53.00			1500	1,919	ATU ta	10/31/2003
REMARKS: Used to house Bio-Microbics FAST 0.5FS, 0.75FS, and 0.9FS ATU									
01-011-BM3-C4	C4	4.00	57.00			2150	2,752	ATU ta	
REMARKS: Used to house Bio-Microbics FAST 1.5FS ATU									
01-011-BM4-C3	C3	3.00	43.00			1600	2,433	ATU ta	10/31/2003
REMARKS: Used to house Bio-Microbics FAST 0.5F, 0.75F, and 0.9F ATU									
01-011-BM5-C3	C3	6.00	66.00			4500	5,909	ATU ta	10/31/2003
REMARKS: Used to house Bio-Microbics FAST 3.0F and 3.0FS ATU									
01-011-BM6-C3	C3	4.00	65.00			4400	5,913	ATU ta	2/17/2004
REMARKS: Used to house Bio-Microbics FAST 4.5F ATU									
01-011-BM7-C4	C4	4.00	63.00	78	154.5	2400	3,021	ATU ta	9/13/2007
REMARKS: Used to house Bio-Microbics FAST 1.5F or S ATU. Inlet and/or outlet can be 4" or 6".									
01-011-BM8-C4	C4	4.00	44.00			1650			7/30/2001
REMARKS: (01-011-29S-C4 converted to ATU tank, 02-05-2012) Used to house Bio-Microbics 1.5 ATU with 750 gallon pretreatment tank.									
01-011-BM9-C4	C4	6.00	53.00			1500			10/31/2001
REMARKS: Converted 01-011-27D-C4, to house Bio-Microbics .5, .75, and .9 ATU. AASHTO H20 traffic loading rated when buried between 18" to 48"									



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

George W. Shephard & Son, Inc.

ACTIVE

Collier

PO Box 202

Naples FL 34106

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		EFFECTIVE GALLONS	TOTAL	APPROVAL	FAMILY
				WIDTH	LENGTH		GALLONS (Pump Tanks)		
11-149-H10P-C3	C3	2.50	65.00	89	157	3309	ATU	10/25/2011	
REMARKS: Houses the Hoot 1000 gpd dosed ATU system (H-1000 AND), needs settling tank									
11-149-H10P-C4	C4	2.50	65.00	89	157	3309	ATU	4/3/2012	
REMARKS: Houses the Hoot 1000 gpd dosed ATU system (H-1000 AND), requires settling tank; 5000 psi concrete									
11-149-H6G-C3	C3	3.00	52.00	74.5	106	1320	ATU	10/24/2011	
REMARKS: Houses either the Hoot 500 or 600 gpd gravity flow ATU (H-500									
11-149-H6P-C3	C3	3.00	52.00	74.5	160	2080	ATU	10/25/2011	
REMARKS: Houses either the Hoot 500 or 600 gpd dosed ATU (H-500 AND, H-600 AND). Needs recirculation for increased nitrogen reduction									



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

H.G. McGrew, Inc.

ACTIVE

3805 Industrial Drive
Bossier City LA 71112

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		EFFECTIVE GALLONS	TOTAL	APPROVAL		FAMILY
							(Pump Tanks)	USE	DATE	
70-121-MM1-C4	C4	0.38	66.00				ATU		3/22/2002	
REMARKS: Used to house the Mighty Mac 500 ATU										
70-121-MM2-C3	C3	0.38	66.00				ATU		10/6/2002	
REMARKS: Used to house the Mighty Mac 750 ATU										
70-121-MM3-C3	C3	0.38	66.00				ATU		10/6/2002	
REMARKS: Used to house the Mighty Mac 600 ATU										



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Howie Concrete Products, Inc.

Active

Monroe

2817 Central Avenue

Big Pine Key, FL 33043

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u> WIDTH LENGTH	EFFECTIVE GALLONS	TOTAL GALLONS (Pump Tanks)	USE	APPROVAL DATE	FAMILY
44-085-08D-C3	C3	2.50	41.00		900			1/23/2004	
REMARKS: Houses the FAST 0.5F short ATU. Houses .250 and .375 RetroFASTunits as INNOVATIVE.									
44-085-11D-C3	C3	2.50	41.00		1050			1/23/2004	
REMARKS: Houses the FAST 0.5F short ATU. Houses .250 and .375 RetroFASTunits as INNOVATIVE.									
44-085-NW1-C3	C3	2.50	54.00					3/22/2002	
REMARKS: Norweco (Singulair 960 and Singulair TNT model) 500/600 gallon per day ATU. Add 1000 gallon pretreatment chamber to become 1000 gallon per day ATU.									
44-085-NW2-C3	C3	2.50	66.00					3/22/2002	
REMARKS: Norweco (Singulair 960 and Singulair TNT model) 750/800 gallon per day ATU. Add 1250 pretreatment chamber to become 1250 gallon per day ATU.									
44-085-NW3-C3	C3	2.50	78.00					3/22/2002	
REMARKS: Norweco (Singulair 960 and Singulair TNT model) 1500 gallon per day ATU (requires minimum 1500 gallon pretreatment tank)									



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Hydro-Action

ACTIVE

8645 Broussard Road

Beaumont TX 77713

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		EFFECTIVE GALLONS	TOTAL	APPROVAL	FAMILY
							GALLONS (Pump Tanks)		
70-118-HA1-C3	C3	0.25	64.00				ATU	9/24/2002	
REMARKS: 500 gallon per day ATU tank-fiberglass									
70-118-HA2-C3	C3	0.25	64.00				ATU	9/24/2002	
REMARKS: 600 gallon per day ATU tank-fiberglass									
70-118-HA3-C3	C3	0.31	64.00				ATU	9/24/2002	
REMARKS: 750 gallon per day ATU tank-fiberglass									
70-118-HA4-C3	C3	0.38	70.00				ATU	9/24/2002	
REMARKS: 1000 gallon per day ATU tank-fiberglass									
70-118-HA5-C3	C3	0.38	80.00				ATU	9/24/2002	
REMARKS: 1500 gallon per day ATU tank-fiberglass									



DEPARTMENT OF HEALTH
 STATE HEALTH OFFICE
 SEPTIC TANK DESIGNATED APPROVAL NUMBERS
 SEPTIC TANK MANUFACTURERS
 run date: 4/5/2012
 Searching for: atu

Mack Concrete Industries

ACTIVE

Lake

Post Office Box 157
 Astatula, FL 34705

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH		GALLONS (Pump Tanks)		
35-015-08D-C3	C3	2.50	42.00			1050		3/22/2002	
REMARKS: Houses Bionest BNC-400 ATU									
35-015-15D-C3	C3	3.00	48.00			1500		3/22/2002	
REMARKS: Houses Bionest BNC-500 ATU and 600 ATU									
35-015-30D-C3	C3	3.00	48.00			2000		3/22/2002	
REMARKS: Houses Bionest BNC-750 ATU									
35-015-64D-C3	C3	4.00	42.00			3500		3/22/2002	
REMARKS: Houses Bionest BNC-1250 ATU									
35-015-72D-C3	C3	4.00	51.00			4300		3/22/2002	
REMARKS: Houses Bionest BNC-1500 ATU									
35-015-CA1-C3	C3	2.50	55.00	62	94		ATU	9/18/2008	
REMARKS: CajunAire 500 gallon per day ATU									
35-015-NW1-C3	C3	2.50	54.00					3/22/2002	
REMARKS: Norweco (Singulair 960 and Singulair TNT model) 500/600 gallon per day ATU. Add 1000 gallon pretreatment chamber to become 1000 gallon per day ATU.									
35-015-NW2-C3	C3	2.20	66.00					3/22/2002	
REMARKS: Norweco (Singulair 960 and Singulair TNT model) 750/800 gallon per day ATU. Add 1250 pretreatment chamber to become 1250 gallon per day ATU.									
35-015-NW3-C3	C3	2.50	78.00					3/22/2002	
REMARKS: Norweco (Singulair 960 and Singulair TNT model) 1500 gallon per day ATU (requires minimum 1500 gallon pretreatment tank)									



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Murrill Tank Service, Inc.

ACTIVE

3621 Alab Club Road

Mobile AL 36605

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		EFFECTIVE GALLONS	TOTAL	APPROVAL		FAMILY
							GALLONS (Pump Tanks)	USE	DATE	
68-135-H10P-C4	C4	2.50	64.00				ATU		8/3/2007	
REMARKS: Houses the Hoot 1000 gpd dosed ATU system										
68-135-H6G-C3	C3	2.50	52.00				ATU		1/8/2007	
REMARKS: Houses either the Hoot 500 or 600 gpd gravity flow ATU system.										
68-135-H6P-C3	C3	2.50	52.00				ATU		1/8/2007	
REMARKS: Houses either the Hoot 500 or 600 gpd dosed or drip irrigation ATU system										



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Norweco

ACTIVE

220 Republic Street

Norwalk OH 44857-1156

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		EFFECTIVE GALLONS	TOTAL	USE	APPROVAL	FAMILY
				WIDTH	LENGTH		GALLONS (Pump Tanks)		DATE	
70-150-NW1-C3	C3	0.38	52.00	78	123	1280	1,430	ATU	11/17/2011	

REMARKS: Polyethylene tank; three joined compartments; used to house ATU Norweco Singulair Green 960-500 or TNT-500, NSF-40 certified for 500 and 600 gpd



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Orengo Systems, Incorporated

ACTIVE

814 Airway Avenue

Sutherlin Or 97479

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u> WIDTH	LENGTH	EFFECTIVE GALLONS	TOTAL GALLONS (Pump Tanks)	APPROVAL USE DATE	FAMILY
70-128-AXRT1-	C3							5/24/2010	
REMARKS: Fiberglass recirculating tank used to house Advantex AX20-RT as part of a 500 gpd ATU, requires 1000 gal minimum pretreatment tank.									
70-128-X100-C3	C3							11/28/2006	
REMARKS: Fiberglass tank used to house AdvanTex AX100 treatment media as part of a 2000 gpd ATU.									
70-128-X20-C3	C3							8/30/2004	
REMARKS: Fiberglass tank used to house AdvanTex AX20 treatment media as part of a 500 gpd ATU.									



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Premier Tech

ACTIVE

1, Avenue Premier

Quebec G5R 6CI C

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		EFFECTIVE GALLONS	TOTAL	APPROVAL	
							(Pump Tanks)	USE	DATE
70-124-650-C3	C3		49.00						4/3/2003

REMARKS: Fiberglass tank-Used to house the STB-650 EcoFlo peat biofilter ATU



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Quanics

ACTIVE

3244 Old LaGrange Road
Crestwood KY 40014

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH		GALLONS (Pump Tanks) USE		
70-116-01-C3	C3	0.25	30.00					8/29/2002	
REMARKS: ATS-SCAT-200 (200 gallon per day ATU) fiberglass									
70-116-02-C3	C3	0.25	30.00					8/29/2002	
REMARKS: ATS-SCAT-400 (400 gallon per day ATU) fiberglass									
70-116-03-C3	C3	0.25	30.00					8/29/2002	
REMARKS: ATS-SCAT-650 (650 gallon per day ATU) fiberglass									
70-116-04-C3	C3	0.25	30.00					8/29/2002	
REMARKS: ATS-SCAT-1050 (1050 gallon per day ATU) fiberglass									
70-116-08-C3	C3	0.31		96	198	3000		9/8/2010	
REMARKS: Fiberglass (FRP) Houses 5000 gpd Quanics Aerocell or Bio-COIR ATU media									



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Rick's Pre Fab

ACTIVE

Dade

25525 SW 141st Ave.

Princeton, FL 33032

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH		GALLONS (Pump Tanks) USE		
13-045-04S-C3	C3	3.00	51.00			900		3/22/2002	
REMARKS: Also houses Bio-Microbics MF 0.5 ATU, when used with a 350 gallon min. settling tank; RTF 0.25 and RTF 0.375 as INNOVATIVE									
13-045-08S-C3	C3	3.00	51.00			1050		1/3/2007	
REMARKS: Also houses Bio-Microbics MicroFAST 0.5 ATU, when used with a 350 gallon min. settling tank. Houses RTF 0.25, RTF 0.375 as INNOVATIVE. Also houses MF 0.75, MF 0.9 ATU when used with 500 gallons min. settling tank. Can house HS 1.0 with 500 pretreatment tank.									
13-045-12S-C3	C3	3.13	51.00			1200		3/22/2002	
REMARKS: Also houses RTF 0.25, RTF 0.375 as INNOVATIVE. Houses Biomicrobics MF 0.5 ATU when used with 350 gallon min. settling tank; MF 0.75, MF 0.9 ATU, when used with 500 gallons min. settling tank. Can house HS 1.0 with 500 pretreatment tank. Also houses Bio-Microbics MF 1.5 ATU when used with 750 gallons min. settling tank.									
13-045-16S-C3	C3	3.13	51.00			1350		3/22/2002	
REMARKS: Also houses Bio-Microbics MF 0.5 ATU, when used with 350 gallons min. settling tank; MF 0.75, MF 0.9, ATU when used with 500 gallons min settling tank. Can house HS 1.0. Also houses MF 1.5 ATU with 750 settling tank.									
13-045-20S-C3	C3	3.13	51.00			1500		3/22/2002	
REMARKS: Also houses Bio-Microbics MF 0.5 ATU when used with 350 gallon min settling tank; MF 0.75, MF 0.9 ATU when used with 500 gallon min settling tank. Can house HS 1.0. Also houses MF 1.5 ATU with 750 gallons min. settling tank.									
13-045-21S-C3	C3	4.00	51.00	62	92	900		8/19/2009	
REMARKS: H10 traffic rating. Also houses Bio-Microbics MF 0.5 ATU, when used with a 350 gallon min. settling tank; RTF 0.25 and RTF 0.375 as INNOVATIVE									
13-045-22S-C3	C3	4.00	51.00	62	106	1050		8/19/2009	
REMARKS: H10 traffic rating. Also houses Bio-Microbics MicroFAST 0.5 ATU, when used with a 350 gallon min. settling tank. Houses RTF 0.25, RTF 0.375 as INNOVATIVE. Also houses MF 0.75, MF 0.9 ATU when used with 500 gallons min. settling tank. Can house HS 1.0 with 500 pretreatment tank									
13-045-23S-C3	C3	4.00	51.00	70	104	1200		8/19/2009	
REMARKS: H10 traffic rating. Also houses RTF 0.25, RTF 0.375 as INNOVATIVE. Houses Biomicrobics MF 0.5 ATU when used with 350 gallon min. settling tank; MF 0.75, MF 0.9 ATU, when used with 500 gallons min. settling tank. Can house HS 1.0 with 500 pretreatment tank. Also houses Bio-Microbics MF 1.5 ATU when used with 750 gallons min. settling tank.									
13-045-24S-C3	C3	4.00	51.00	73	122	1500		8/19/2009	
REMARKS: H10 traffic rating. Also houses Bio-Microbics MF 0.5 ATU when used with 350 gallon min settling tank; MF 0.75, MF 0.9 ATU when used with 500 gallon min settling tank. Can house HS 1.0. Also houses MF 1.5 ATU with 750 gallons min. settling tank									
13-045-31S-C4	C4	6.00	51.00	66	96	900		9/22/2009	
REMARKS: H20 traffic rating. Also houses Bio-Microbics MF 0.5 ATU, when used with a 350 gallon min. settling tank; RTF 0.25 and RTF 0.375 as INNOVATIVE									
13-045-32S-C4	C4	6.00	51.00	66	110	1050		9/22/2009	
REMARKS: H20 traffic rating. Also houses Bio-Microbics MicroFAST 0.5 ATU, when used with a 350 gallon min. settling tank. Houses RTF 0.25, RTF 0.375 as INNOVATIVE. Also houses MF 0.75, MF 0.9 ATU when used with 500 gallons min. settling tank. Can house HS 1.0 with 500 pretreatment tank									
13-045-33S-C4	C4	6.00	51.00	74	108	1200		9/22/2009	
REMARKS: H20 traffic rating. Also houses RTF 0.25, RTF 0.375 as INNOVATIVE. Houses Biomicrobics MF 0.5 ATU when used with 350 gallon min. settling tank; MF 0.75, MF 0.9 ATU, when used with 500 gallons min. settling tank. Can house HS 1.0 with 500 pretreatment tank. Also houses Bio-Microbics MF 1.5 ATU when used with 750 gallons min. settling tank.									



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Rick's Pre Fab

ACTIVE

Dade

25525 SW 141st Ave.

Princeton, FL 33032

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		EFFECTIVE GALLONS	TOTAL	APPROVAL		
				WIDTH	LENGTH		GALLONS (Pump Tanks)	USE	DATE	FAMILY
13-045-34S-C4	C4	6.00	51.00	77	126	1500			9/22/2009	

REMARKS: H20 traffic rating. Also houses Bio-Microbics MF 0.5 ATU when used with 350 gallon min settling tank; MF 0.75, MF 0.9 ATU when used with 500 gallon min settling tank. Can house HS 1.0. Also houses MF 1.5 ATU with 750 gallons min. settling tank



DEPARTMENT OF HEALTH
 STATE HEALTH OFFICE
 SEPTIC TANK DESIGNATED APPROVAL NUMBERS
 SEPTIC TANK MANUFACTURERS
 run date: 4/5/2012
 Searching for: atu

Sebring Septic Tank & Precast Co. ACTIVE Highlands

8037 Commercial Blvd.
 Sebring FL 33870

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH		GALLONS (Pump Tanks) USE		
28-O15-03D-C4	C4	3.00	55.00			1050		11/9/2001	
REMARKS: Houses Bionest BNC-400 ATU. Monolithic baffle									
28-O15-06D-C4	C4	3.00	49.50			1250		11/9/2001	
REMARKS: Houses Bionest BNC-500 ATU. Monolithic baffle									
28-O15-08D-C3	C3	3.00	53.30			1050		11/9/2001	
REMARKS: Houses Bionest BNC-400 ATU. Also available in 4" and 6" thick wall tanks									
28-O15-10D-C4	C4	6.00	53.30			1050		4/22/2002	
REMARKS: Houses Bionest BNC-400 ATU. H-20 traffic rated									
28-O15-16D-C3	C3	3.00	57.80			1250		4/22/2002	
REMARKS: Houses Bionest BNC-500 ATU.									
28-O15-17D-C3	C3	4.00	57.80			1250		8/2/2002	
REMARKS: Houses Bionest BNC-500 ATU.									
28-O15-19D-C3	C3	3.00	44.00			1500		4/22/2002	
REMARKS: Houses Bionest BNC-600 ATU. Monolithic baffle									
28-O15-24D-C4	C4	6.00	42.00	90	130	1500		4/22/2002	
REMARKS: w/o slide-in baffle, can house Biomicrobics MF 1.5 1,500 gpd ATU when used with 750 gallon min pretreatment tank (02/26/10) H-20 traffic rated									
28-O15-24S-C4	C4	6.00	42.00	90	130	1500		4/22/2002	
REMARKS: Can house Biomicrobics MF 1.5 1,500 gpd ATU when used with 750 gallon min pretreatment tank (02/26/10). H-20 traffic rated									
28-O15-34D-C4	C4	6.00	56.00			2000		4/22/2002	
REMARKS: Houses Bionest BNC-750 ATU. H-20 traffic rated									
28-O15-35D-C4	C4	4.00	55.50			2000	2,455	11/19/2004	
REMARKS: Houses Bionest BNC-750 ATU.									
28-O15-46D-C4	C4	6.00	70.00			2500		12/12/2000	
REMARKS: Houses Bionest BNC-1000 ATU. H-20 traffic rated									
28-O15-AA1-C3	C3	2.50	52.50	0	0	500		6/30/2006	
REMARKS: Aqua Aire 500 gallon per day ATU									
28-O15-AA2-C3	C3	2.50	54.00	0	0	800		10/5/2006	
REMARKS: Aqua Aire 800 gallon per day ATU									
28-O15-AA3-C3	C3	2.50	52.00	0	0	600		4/13/2007	
REMARKS: Aqua Aire 600 gallon per day ATU									
28-O15-AA4-C3	C3	2.50	52.00	74	114	1000		5/7/2008	
REMARKS: Aqua Aire 1000 gallon per day ATU									



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Sebring Septic Tank & Precast Co.

ACTIVE

Highlands

8037 Commercial Blvd.

Sebring FL 33870

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	TOP EXTERIOR		EFFECTIVE GALLONS	TOTAL	APPROVAL DATE	FAMILY
				WIDTH	LENGTH		GALLONS (Pump Tanks) USE		
28-O15-AA5-C3	C3	2.50		0	0			8/25/2010	
REMARKS: Aqua Aire 1200 gallon per day ATU									
28-O15-AW1-C3	C3	2.50	52.00			500		8/19/2003	
REMARKS: American Wastewater 500 gallon per day B.E.S.T. 1 ATU									
28-O15-AW2-C3	C3	2.50	54.00			800		2/3/2004	
REMARKS: American Wastewater 800 gallon per day B.E.S.T. 1 ATU									
28-O15-AW3-C3	C3	2.50	82.00			1200		2/3/2004	
REMARKS: American Wastewater 1200 gallon per day B.E.S.T. 1 ATU									
28-O15-AW4-C3	C3	2.50	61.00	0	0	1000		6/30/2006	
REMARKS: American Wastewater 1000 gallon per day B.E.S.T. 1 ATU									
28-O15-NW1-C3	C3	2.50	51.00					8/23/2002	
REMARKS: Norweco (Singulair 960 and Singulair TNT model) 500/600 gallon per day ATU. Add 1000 gallon pretreatment chamber to become 1000 gallon per day ATU.									



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Southern Precast, Inc. (Moultrie, G

ACTIVE

450-C GA Hwy 33 S

Moultrie, GA 31788

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		EFFECTIVE GALLONS	TOTAL	APPROVAL		FAMILY
				WIDTH	LENGTH		GALLONS (Pump Tanks)	USE	DATE	
69-070-08D-C3	C3	2.50	44.00			1050			3/22/2002	
REMARKS: w/o slide-in baffle also approved: to house BIO-Microbics MF 0.5 ATU, when used with 350gallon min. settling tank; BM MF 0.75 &MF 0.9 ATU when used with a 500 gallon min. settling tank.										
69-070-08S-C3	C3	2.50	44.00			1050			3/22/2002	
REMARKS: Also approved to house BIO-Microbics MF 0.5 ATU, when used with 350gallon min. settling tank; BM MF 0.75 &MF 0.9 ATU when used with a 500 gallon min. settling tank.										
69-070-NW1-C3	C3	3.00	41.00	0	0		ATU		10/2/2007	
REMARKS: Norweco (Singular 960 and Singular TNT model) 500/600 gallon per day ATU. Also 1000 Gallon per day ATU with 1000 gallon pretreatment tank.										



DEPARTMENT OF HEALTH

STATE HEALTH OFFICE

SEPTIC TANK DESIGNATED APPROVAL NUMBERS

SEPTIC TANK MANUFACTURERS

run date: 4/5/2012

Searching for: atu

Third Generation Plumbing

ACTIVE

Monroe

3980 Overseas Highway

Marathon FL 33050

TANK NUMBER	CATEGORY	WALL THICKNESS	LIQUID DEPTH	<u>TOP EXTERIOR</u>		EFFECTIVE GALLONS	TOTAL	APPROVAL	FAMILY
							GALLONS (Pump Tanks)		
44-122-05-C3	C3	3.00	54.00				ATU	1/27/2003	
REMARKS: Used to house the 500 gallon per day AquaKlear ATU.									
44-122-07-C3	C3	3.00	61.00				ATU	5/2/2003	
REMARKS: Used to house the 750 gallon per day AquaKlear ATU									
44-122-08-C3	C3	3.00	61.00				ATU	7/27/2004	
REMARKS: Used to house the 800 gallon per day AquaKlear ATU									